



Cadillac
Fairview

FIRE PROTECTION SYSTEM BYPASS PERMIT

GENERAL INFORMATION

TENANT _____

TENANT CONTACT _____ TELEPHONE _____

BUILDING _____ FLOORS _____

DATE OF REQUEST _____

GENERAL CONTRACTOR

COMPANY _____

CONTACT NAME _____ TELEPHONE _____

CELLULAR _____ EMAIL _____

SUB CONTRACTOR

COMPANY _____

CONTACT NAME _____ TELEPHONE _____

CELLULAR _____ EMAIL _____

PROJECT INFORMATION

DATE OF WORK - FROM _____ TO _____

TIME OF WORK - FROM _____ TO _____

SYSTEM TO DISABLE:

- SMOKE DETECTOR
 HEAT DETECTOR
 PULL STATION
 SPRINKLER/BACKFLOW
 FIRE PUMP
 GENERATOR
 VERIFICATIONS
 INSTALLATION/RELOCATION AND
 TESTING OF FIRE SYSTEM DEVICES

Note: 48 hours notice required for Smoke Detectors, Heat Detectors, Pull Stations, Sprinklers / Backflows, Fire Pump Tests, and Generator Tests. 72 hours notice required for the installation/relocation and testing of Smoke Detectors, Speakers, and Fire Phones. 7 days notice for the installation/relocation and testing of Pull Stations, Maglocks, and Heat Detectors and any Verifications.

DESCRIPTION OF WORK:

For Office Use Only

Received by _____ Date _____

Comments _____
